

QUESTIONS/RESPONSES For: RFP no.1924R Access Control Hardware for KSU Housing

Line item 1 – E996L-NL-R/V US26D 06 – the NL designates a rigid lever which is not available on the electronic lock. Please advise which lever

Response: Please note that the night latch feature is available on an electrified trim. Here is the description of the trim. Von Duprin E996L-R/V-06 Electrified Breakaway Lever Trim for 98/99 Series Exit Device.

Line items 2 and 4 are discontinued – suggested replacement for both is BEA 10MS41 series.

Response: Unless there is a EOL, end of life, or some other information stating a discontinuation of those switches, I have no information at this time stating that they are discontinued. If the vendor does have something stating that they are discontinued, please have them pass it along to us.

Line item 20 -LCN 6400 is a plug in automatic operator, please confirm that this is what is required; or if you require hardwire or battery actuator kits with the operator.

Response: To further clarify the item, we are looking to purchase here is a corrected part number that will answer the vendors question. Series 6400 Model 6440-2210 689